

(1)

# EC Type-Examination Certificate

(2) Devices and protective systems intended for use in hazardous areas - **Directive 94/9/EC**

(3) EC Type-Examination Certificate



## TÜV 09 ATEX 7709 U

(4) Components: **Stainless steel enclosures: APD series**

(5) Manufacturer: **IRINOX S.p.A.**

(6) Address: **Via caduti nei Lager, 1 I – 31015 Conegliano (TV)**

(7) The design of this component and its different admissible models are specified in the appendix to this type-examination certificate.

(8) The TÜV CERT-Zertifizierungsstelle for ex-protected products of TÜV Rheinland Industrie Service GmbH, TÜV Rheinland Group, as notified body No. 0035 in accordance with Article 9 of the directive of the Council of the European Communities of 23 March 1994 (94/9/EC), certifies the compliance with the essential safety and health requirements for the design and the construction of devices and protective systems intended for use in hazardous areas acc. to Annex II of the directive.

The results of the examination are recorded in confidential Test Report No. 296/Ex709.00/09.

(9) The essential safety and health requirements are met through compliance with

**EN 60079-0: 2006; EN 60079-7: 2007**

**EN 61241-0: 2006; EN 61241-1: 2004**

with the exception of the requirements listed in item 18 of the annex.

(10) The character "U" behind the certificate number indicates that this EC type-examination certificate must not be confused with an EC type-examination certificate for an device or a protective system. This certificate may only be used as a basis for the certificate of a device or protection system.

(11) This EC Type-Examination Certificate relates only to the design and construction of the specified component in accordance with Directive 94/9/EC. Further requirements of this directive apply to the production and the supply of this component. These requirements are not covered by this certificate.

(12) The marking of the component must include the following:

	<b>II 2 G</b>	<b>Ex e II</b>
	<b>II 2 D</b>	<b>Ex tD A21 IP65</b>

TÜV CERT-Zertifizierungsstelle für Explosionsschutz

Cologne, 08. July 2009

Dipl. Ing. K. Wettingfeld



Translation!!

This EC type examination certificate is not valid without signature and stamp.

This EC type examination certificate may only be distributed without changes. Extracts and changes require the approval of TÜV CERT-Zertifizierungsstelle für Ex-Schutz-Produkte

TÜV Rheinland Industrie Service GmbH Am Grauen Stein 51105 Köln  
Tel. +49 (0) 221 806-0 Fax + 49 (0) 221 806 114

www.tuv.com



**TÜVRheinland®**  
Genau. Richtig.